



Nr.	Nosaukums	Izmērs	Parametri	Piezīmes
1.	Kamsstrup MUL.TICAL	DN40	Qn=10m ³ /h	T1
2.	Danfoss AFP/VFG 21-40	DN40	Kvs=20	T2
3.	Danfoss VM-2-32, AMV20	DN32	Kvs=10	Apkure
4.	ALFA LAVAL CB77-60H	DN65		Apkure
5.	Wilo TOP/ED 40/1-10	DN32	Kvs=10	Apkure
6.	Danfoss VM2-32, AMV33	DN32		Kū.
7.	ALFA LAVAL CB27-100H	DN25		Kū.
8.	Wilo Star-Z 25/6 CircoStar	DN25		Kū. cirkulācija
9.	Wilo Star-Z 25/6 CircoStar	DN25		Kū.
10.	Buderus Logalux SF500			Kū. akumulācijas ivertne
11.	Reflex			140litri
12.	Reflex			25 litri

Pasūtītājs:		SIA "BALOŽU KOMUNĀLĀ SAIMNIECĪBA"		Pasūtījuma numurs:	
Amats	Uzvārds	Sert.Nr.	Paraksts	Datums	Objekts:
Izpildītāja	XXXXXXXXXX	XXXXXXXXXX		01.01.2012.	SMILŠU IELA 2, BALOŽI, ĶEKAVAS NOVADS
					Rasējuma nosaukums:
					Skats 2
					Stadija
					T.P.
					Lapa
					Mērogs
					SM-07
					Izpildītājs:
					SALTIMMEHĀNIKA (SM)